



Wintergreen Fire and Rescue Standard Administrative Policy	
Subject:	Hose Packing
Reference Number:	FIRE 02-005
Effective Date:	22-May-05
Last Revision Date:	3-Mar-21
Signature of Approval	Curtis Sheets, Chief

Purpose:

To have uniform procedures for pulling and packing hose.

Policy:

The preconnects and crosslays will be packed using a minuteman hose load. To deploy this hose load, put the stack with the nozzle over one shoulder and grab the two loops (where applicable) from the second stack with your free hand and walk away from the apparatus. Release the loops, as necessary while walking and flaking the hose. Reference pictures below for double stacked (Figure 1) and single stacked (Figure 2) options.

The front crosslay shall be packed to be pulled out on the operators (left) side of the engine and the back crosslay will be packed to be pulled off the officers (right) side.

The front trash line will be packed as needed to fit in the front tray for this line.

The 1 3/4" rear preconnect attack line will be on the officers (right) side and the 2 1/2" attack line will be packed on the operators (left) side where applicable.

Figure 1



Double Stacked Minuteman.

Figure 2



Single Stacked Minuteman.